



OFFICE OF THE DEPUTY FIRE OFFICER,
BHUBANESWAR CIRCLE, BHUBANESWAR.

No. 415 /BBS. CIR

Dt.09.04.2019

To

Sri Lala Susanta Ray
Managing Trustee of Sai Anandam Trust,
Plot no-2590, 2591 & others,
Mouza-Bhuasuni, Chandaka,
Khurdha-754005

Ref: Your letter no. Nil, dt.13.03.2019


Sub: Issuance of Fire Safety Certificate in respect of ^{Sri Sathya} Sai Anandam School, Over plot no-2590, 2591 & others, Mouza-Bhuasuni, Chandaka, Khurda.

With reference to the subject cited above this is to intimate that you have applied for issuance of Fire Safety Certificate in respect of ^{Sri Sathya} Sai Anandam School, (height of Hostel building is 3.70 mtrs), Over plot no-2590, 2591 & others, Mouza-Bhuasuni, Chandaka, Khurda.

As per Odisha Fire Prevention and Fire Safety Rules, 2017 & Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019, vide Govt. of Odisha, Home Department Notification L.No-10573/Home, Bhubaneswar, dtd.06.03.19, Educational buildings as mentioned below required Fire Safety Certificate.


- (i) of twelve meters or more in height from ground level or,
- (ii) of built up area of one thousand square meters or above or,
- (iii) of three storied or,
- (iv) all underground or partially underground structures of five hundred square meters or above used for any purpose of occupancy.

Hence, Fire Safety Certificate is not required for your aforesaid Educational building.


09/04/2019
(R.C. Majhi)

Deputy Fire Officer,
BBSR Circle, Bhubaneswar.

Deputy Fire Officer
Bhubaneswar Circle, Bhubaneswar


24/09/2021
Deputy Fire Officer
Bhubaneswar Circle, Bhubaneswar